

MUNICIPAL UTILITIES BOARD OF THE CITY OF ALBERTVILLE
SPECIFICATIONS FOR RESIDENTIAL UNDERGROUND
SERVICE REQUIREMENTS 200 AMP

MUB Will Make
These Connections

Note #1 Use Penetrox On All
Aluminum Connections

Note #2 Do not Install Shielded
Entrance Cable in Conduit
(Gray Insulation)

Note #3 Call One Day
Minimum Before Digging To
Schedule All Underground
Services

Note #4 Must have a
minimum of 18" leads

Note #5 Must have an
insulated neutral

Note #6 If conduit has a splice,
it must be a minimum of 4 feet
from the meter base

Note #7 Customer
Responsible for Opening and
Closing all Ditches

Hot Leg
Connections Into
Structure/
Disconnect

Conduit With Wire
or Service
Entrance Cable
with Connector 4/0
Aluminum or 3/0
Copper

Neutral
Connection Into
Structure/Disconnect
Same Size or 1/2
Size of Hot Leg
Connections.

#4 Solid Bare
Copper To Ground
Rod

Customer Provides: 2 1/2" PVC
Male Adapter Grey Schedule 40
Pipe to Bottom of Ditch, with one
Sweeping Elbow.

© Copyright 2005 MUB of Albertville
Permit required before any services are hooked up

